

**Recordkeeping: Asphalt Plant Permit-by-Rule
Diesel Fuel Limitations (One form per week)**

Facility Name _____

Monday (month/day/year):	Amount Used or Time in Operation: Gallons or hours
Tuesday (month/day/year):	Amount Used or Time in Operation: Gallons or hours
Wednesday (month/day/year):	Amount Used or Time in Operation: Gallons or hours
Thursday (month/day/year):	Amount Used or Time in Operation: Gallons or hours
Friday (month/day/year):	Amount Used or Time in Operation: Gallons or hours
Saturday (month/day/year):	Amount Used or Time in Operation: Gallons or hours
Sunday (month/day/year):	Amount Used or Time in Operation: Gallons or hours

Diesel Fuel Used or Generator(s) Time in Operation _____gallons or hours

Calendar Month Total _____gal/hours Is this value in compliance?_____

12 Consecutive Monthly Total _____gal/hours Is this value in compliance?_____

Based on my choice of monitoring, I am limited to one of the following limits (next page):

Option One: Limiting based on Fuel Amount

You will not combust more than 75,000 gallons of diesel fuel per calendar month and 250,000 gallons of diesel fuel per consecutive twelve (12) months

011.04

a) Option Two: Limiting based on Operating Time

The maximum amount of time the generator(s) will be permitted to be in operation is shown below:

$$\frac{75,000 \text{ gallons}}{\text{month}} \times \frac{1}{\boxed{}} = \boxed{}$$

Max. Operating Hours per Month

Total Generator Fuel Intake (gal/hr)

$$\frac{250,000 \text{ gallons}}{\text{year}} \times \frac{1}{\boxed{}} = \boxed{}$$

Max. Operating Hours per Year

Total Generator Fuel Intake (gal/hr)

011.04